

EC TYPE-EXAMINATION CERTIFICATE

Acting under the Warenwetbesluit liften issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Besluit no. A&G/W&P/03 56126 of October 15th, 2003

Certificate nr. : NL 07-400-1002-034-04 Revision nr.: -

Description of the product : Door locking device for swing doors

Trademark, type : Can-lift, CL 01 M and CL 01 MD

Name and address of the manufacturer : Can-Lift Asansör Sanayi ve TLC. LTD. ŞTİ.
Y.Dudullu Mah. Bayraktar Bulvari Caddesi Hattat Sok. No. 10
Ümraniye 34775 Istanbul, Turkey

Name and address of the certificate holder : Can-Lift Asansör Sanayi ve TLC. LTD. ŞTİ.
Y.Dudullu Mah. Bayraktar Bulvari Caddesi Hattat Sok. No. 10
Ümraniye 34775 Istanbul, Turkey

Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC, EN 81-1/2

Test laboratory : Can lift, Istanbul, Turkey
Liftinstituut, Amsterdam, The Netherlands

Date and number of the laboratory report : None

Date of EC type-examination: March 2007 - April 2007

Annexes with this certificate : Report belonging to the EC type-examination certificate
nr.: NL 07-400-1002-034-04

Additional remarks : The door lock shall be used for swing doors only.
The door locking device shall be applied within rated current and
voltage 0,5A / 220 VAC.
Max. door gap at locking side shall be 5.0 mm

Conclusion : The safety component meets the requirements of the Lifts
Directive 95/16/EC taking into account any additional remarks
mentioned above

 **COMFORT-LIFT**
Comfort-Lift Magyarország Kft.
H-1202 Budapest, Fiume u. 15.
Adószám: 23284245-2-43 Cg.: 01-09-958345
www.comfort-lift.hu



Issued in Amsterdam
Date of issue : April 2, 2007

Liftinstituut Holding B.V.
managing director